Where Do I Find Everything I Need for **Process Measurement and Control?** OMEGA...Of Course!

TEMPERATURE

- Thermocouple, RTD & Thermistor Probes, Connectors, Panels & Assemblies
 Wire: Thermocouple, RTD & Thermistor
 Calibrators & Ice Point References

- © Connectors, ranges ac. ...

 Whire: Thermocouple, RTD & Thermistor

 Calibrators & Ice Point References

 Recorders, Controllers & Process Monitors

 Infrared Pyrometers

PRESSURE, STRAIN AND FORCE

- Transducers & Strain GaugesLoad Cells & Pressure Gauges
- Displacement Transducers
 Instrumentation & Accessories

FLOW/LEVEL

- ☑ Rotameters, Gas Mass Flowmeters & Flow Computers
 ☑ Air Velocity Indicators
- Turbine/Paddlewheel Systems Totalizers & Batch Controllers

pH/CONDUCTIVITY

- Controllers, Calibrators, Simulators & Pumps

DATA ACQUISITION

- ☐ Data Acquisition & Engineering Software
 ☐ Communications-Based Acquisition Systems
 ☐ Plug-in Cards for Apple, IBM & Compatibles
- ☐ Plug-in Cards for Apple, IBM
 ☐ Datalogging Systems
 ☐ Recorders, Printers & Plotters

HEATERS

- ☐ Heating Cable
 ☐ Cartridge & Strip Heaters
 ☐ Immersion & Band Heaters
 ☐ Flexible Heaters
 ☐ Laboratory Heaters

ENVIRONMENTAL MONITORING AND CONTROL

- Metering & Control Instrumentation
 Refractometers
 Pumps & Tubing
 Air, Soil & Water Monitors
 Industrial Water & Wastewater Treatment
- PH, Conductivity & Dissolved Oxygen Instruments

M-3444 / 0799





OF OMEG! http://www.omega.com

LVU-90 Series Ultrasonic Level Transmitter

i information constained in this document is believed to be conrect but ONEGA Engineering, inc. accepts no liability for any errors it con-rs, and exerveds the tight expeditabilities without notice. RRINIG: These products are not designed for use in, and should not be used for, patient connected applications.

United Kingdom: ISO 9002 Certified

France:

Canada:

:ASU

*** The policy of OMEGA to comply with all worldwide selectings OMEGA will add the CE mark to every appropriate device upon or of its products to the European New Approach Directives. OMEGA will add the CE mark to every appropriate device upon certification.

25 Swannington Road, Broughton Astley, Leicestershire, LE9 6TU, England FAX: 44 (1455) 285520 FAX: 44 (1455) 283912 FAX: 44 (161) 777-6622 PO. Box 7. Omega Drive, Irlam, Manchester, M44 5EX, England Tel: 44 (161) 777-6611

Toll Free in Germany: 0130 11 21 66 e-mail: germany®omega.com

FAX: 49 (07056) 8540

Germany/Austria: Daimlerstrasse 26, D-75392 Decke Tel: 49 (07056) 3017 moɔ.gemo®əɔnsrì :fism-e

Toll Free in France: 0800-4-06342 FAX: (33) 130-699-120 9, rue Denis Papin, 78190 Trappes Tel: (33) 130-621-400

e-mail: czech@omega.com FAX: 42 (69) 6311114 Ostravska 767, 733 01 Karvina Tel: 42 (69) 6311899 Czech Republic:

е-тан: пьтотеда.сот Postbus 8034, 1180 L.A Amstelveen, The Vietherlands Tel: (31) 20 6418405 FAX: (31) 20 6434643 Toll Free in Benelux: 06 0993344

Benelux:

Servicing Europe:

e-mail: espanol@omega.com En Español: (203) 359-1660 ext: 2203 FAX: (95) 203-359-7807 Tel: (95) 800-TC-OMEGA2st гэди ушецсэ:

| Company | Comp

For immediate technical or application assistance:

тоэ.sgэто®оваа.сот-PAX: (514) 856-6886 8269-958 (FIG) :I-9I 976 Bergar Laval (Quebec) H7L 5A1

e-mail: info®omega.com 161: (203) 329-1660

FAX: (203) 359-7700 One Omega Drive, Box 4047 Stamford, CT 06907-0047 ISO 9001 Certified

Servicing North America:

поо в да сош

moo.ega.com.vww//:qmn OMEGAnet On-Line Service

ASSIMOTO omega.com OMECA's policy is to make running changes, not model changes, wherever an improvement is possible. This altors due usculment the section of the description of the production of the production

1. P.O. number 10 cover the COST of the tepalt, A Model and serial number of product, and 3. Repair instructions and/or specific products relative to the product.

FOR <u>NON-WARRANTY</u> REPAIRS, consult the following information available BEFORE contacting OMEGA:

Repair instructions and/or specific problems relative to the product. 2. Model and serial number of the product under warranty, and

P.O. number under which the product was PURCHASED,

FOR WARRAUTY RETURNS, please have the following information available BEFORE contacting OMEGA:

Direct all warranty and repair requests/inquiries to the OMEGA Customer Service Destructs of the OMEGA Customer Service Department EEFORE ERTURNING ANY PRODUCT(S) TO OMEGA, PURCHARER MUST OBFINIA MAUTHORIZED RETURNING KINS) UNINBER FROM OMEGA'S CUSTOMER SERVICE STOWN AUTHORIZED RETURNING KINS). The assigned AR number about the outside of the cultum package and on any correspondence. The purchaser is responsible for shipping charges, freight, insurance and proper packaging to prevent any and a statement of the purchaser is responsible for shipping charges, freight, insurance and proper packaging the purchaser is responsible for shipping charges, freight, insurance and proper packaging the purchaser is responsible for shipping charges. The purchaser is responsible for shipping charges and proper packaging the purchaser is responsible for shipping charges.

RETURN REQUESTS / INQUIRIES

COMDITIONS: Equipment soid by OMECA is not intended to be used, nor shall it be used: (1) as a "Basic COMDITIONS. Equipment soid by OMECA is not intended to be used in or with any nuclear installation or activity, or (2) in medical applications or used on humans, or misused in any way, OMECA assumes no responsibility as set forth in our basic WARRANTY DISCLAIMER ianguage, and additionally, purchaser will indemnify DMECA and not out of the use of the Product(s) in our asset where the product of th upon which liability is based. In no event shall OMEGA be liable for consequential, incidental or spe-cial damages.

OMECA is pleased to offer suggestions on the use of its various products. However, OMECA neither season to offer suggestions on the use of its various products. However, and stanges that result from the use of its products in accordance with information provided by OMECA, alther verbal or writ-ome and its products in accordance with information provided by OMECA, alther verbal or writ-OMECA where the products in accordance with information provided by OMECA, and the products of defects of the products in accordance with information provided by OMECA, and the products of defects of the products of the products of the products of defects of the products of the products of defects of the products of the product of the products of the products

OMECA ENGINEERING, INC. warrants this unit to be free of defects in materials and workmanship for a period of 13 months from the period of 14 months from the per

■ WARRANTY/DISCLAIMER ■



SPECIFICATIONS

Step One

Range: 3.6" to 6' (9 cm to 1.8 m)
Accuracy: ± .25% of span in air
Resolution: 0.125" (3 mm)
Frequency: 83 kHz (nominal)
Pulse rate: 2 pulses per second

Beam width: 8° conical
Dead band: 3.6" (9 cm)
Supply voltage: 12-36 VDC

Max loop resistance: 600 Ohms @ 36 VDC Signal output: 4-20 mA, 12-36 VDC Fail-safe diagnostics: Reverts to 22 mA

LED flashing

Temperature rating: F: -40° to 140°

C: -40° to 60°

Temp. compensation: Automatic over entire range

Pressure rating: 30 psi (2 bar) @ 25 °C., derated @ 1.667 psi

(0.113 bar) per °C. above 25 °C.

Enclosure rating: NEMA 4X / IP65

Enclosure material: Polypropylene, U.L. 94VO

Transducer materials: PVDF

Mounting threads: 3/4" NPT for LVU-91

3/4" G for LVU-92

Mounting gasket: Viton (3/4" G) LVU-92 only

Conduit connection: 1/2" NPT


CE compliance: EN 50082-2 immunity


EN 55011 emission


(pending)

About Ultrasonic Technology:


An ultrasonic sound wave is pulsed five times per second from the base of the transducer. The sound wave reflects against the process medium below and returns to the transducer. The microprocessor based electronics measures the time of flight between the sound generation and receipt, and translates this figure into the distance between the transmitter and process medium below.












Range Feet	Radius Inches	Radius cm
1	1.2	3.1
2	2.1	5.2
3	2.9	7.3
4	3.7	9.5
5	4.9	11.6
6	5.4	13.7



SAFETY PRECAUTIONS

Step Two



🗥 About this Manual:

PLEASE READ THE ENTIRE MANUAL PRIOR TO INSTALLING OR USING THIS PRODUCT. This manual includes information on the LVU-90 series continuous non-contact level transmitter from OMEGA. Please refer to the part number located on the sensor label to verify the exact model which you have purchased.



User's Responsibility for Safety:

OMEGA manufactures a wide range of liquid level sensors and technologies. While each of these sensors is designed to operate in a wide variety of applications, it is the user's responsibility to select a sensor model that is appropriate for the application, install it properly, perform tests of the installed system, and maintain all components. The failure to do so could result in property damage or serious injury.



Proper Installation and Handling:

Because this is an electrically operated device, only properlytrained staff should install and/or repair this product. Use a proper sealant with all installations. Note: Always install the 3/4" Viton gasket with the LVU-92. The G threaded version will not seal unless the gasket is installed properly. Never overtighten the transmitter within the fitting. Always check for leaks prior to system start-up.



🗥 Wiring and Electrical:

A supply voltage of 12-36 VDC is used to power the transmitter. The sensor systems should never exceed a maximum of 36 volts DC. Electrical wiring of the sensor should be performed in accordance with all applicable national, state, and local codes.



Material Compatibility:

The enclosure is made of Polypropylene (PP). The transducer is made of Polyvinylidene Fluoride (PVDF). Make sure that the model which you have selected is chemically compatible with the application liquids it will contact.



Enclosure:

While the transmitter housing is liquid-resistant when installed properly, it is not designed to be immersed. It should be mounted in such a way that the enclosure and diaphragm do not come into contact with fluid.



🗥 Make a Fail-Safe System:

Design a fail-safe system that accommodates the possibility of transmitter or power failure. In critical applications, OMEGA recommends the use of redundant backup systems and alarms in addition to the primary system.



Flammable, Explosive and Hazardous Applications:

The LVU-90 series transmitter systems should not be used within flammable or explosive applications.



∠! Warning ∠!

Always install the 3/4" Viton gasket with the LVU-92. The LVU-92 G threaded version will not seal unless the gasket is installed properly.


WIRING

Step Three

Wiring to Terminal:

The LVU-90 arrives from the factory pre-calibrated and pre-assembled. Use the following instructions below for wiring to the LVU-90.

- 1. First, remove the cap of the transmitter:
- 2. Look for the terminal block with two terminals.




- 3. Remove the terminal block to wire the LVU-90. The terminal to the right is positive and the terminal to the left is negative.
- 4. When finished attaching the wires, assemble the LVU-90 using steps 1 - 3 in reverse.

WIRING

Step Four


Follow the instructions in Step 3 for wiring to the LVU-90.

Wiring to an OMEGA Continuous Controller (LVCN-51):
 Connect the (+) terminal to the positive 24 VDC, 25 mA terminal on the controller. Connect the (-) terminal to the GND terminal on the continuous controller (See illustration below). Check LVCN-51 instruction manual for setting the LVCN-51 for loop powered




2. Wiring to a Two-Wire Loop Powered Indicator:

The LVCN-90 requires 12-36 VDC power and an indicator which receives a 4-20 mA current input. Connect the (+) terminal of the LVCN-90 transmitter to the positive VDC terminal on the power supply. Connect the (-) terminal on the LVCN-90 to the (+) terminal on the loop indicator. Connect the (-) of the loop indicator to the (-) of the power supply (See illustration below).



3. Wiring to a Typical PLC:

The LVCN-90 requires a PLC which provides a 12-36 VDC excitation and receives a 4-20 mA current input. Connect the (+) terminal of the LVCN-90 transmitter to the positive VDC power terminal. Connect the (-) terminal on the LVCN-90 to the (+) channel on the PLC. Connect the (-) of the PLC to the (-) of the power terminal (See illustration below).




* 250 Ω resistor typically internal to PLC

INSTALLATION

Step Five

The LVCN-90 transmitter may be installed through the top wall of a tank. Installation requires a 3/4" NPT fitting or blind flange.

- 1. Install the appropriate 3/4" fitting in the top wall of the tank. Prior to installation, make sure that the fitting has been installed properly and checked for leaks. Use a proper sealant at the time of installation to ensure a liquid-tight seal. Secondly, make sure that the fitting's threads are not damaged or worn.
- 2. Insert the Transmitter into the fitting and tighten to hand tight.
- Always check for leaks prior to system start-up. To ensure proper installation, a complete leak test and simulation of actual process conditions should be preformed.




⚠ Warning **⚠**

Do not install the LVCN-90 in pressurized applications above 30 psi

Always install the 3/4" Viton gasket with the LVCN-92. The LVCN-92 G threaded version will not seal unless the gasket is installed properly erly and checked for leaks.

Use a proper sealant at the time of installation to ensure a liquidtight seal. Secondly, make sure that the fitting's threads are not damaged or worn.




CALIBRATION

Step Six


The LVCN-90 is factory calibrated with a fixed measurement span of 6 feet. The 4 mA position is located 72" from the transducer face. The 20 mA position is located 3.6 inches from the transducer face. Refer to the current to distance and distance to current conversion charts in step seven for reading the current output.

- 1. Connect a multimeter in series to read the current output.
- Verify that as the distance from the liquid to the LVCN-90 increases, the current signal decreases.
- 3. Verify that as the distance from the liquid to the LVCN-90 decreases, the current signal increases.



LED Indication

The LVCN-90 features a single LED indicator which is used for power and fail-safe indication. During normal operation, the LED will be ON continuously to indicate that the transmitter has power and a strong echo signal return strength. Should the LED begin to FLASH, it indicates that the transmitter has no signal return strength and the device has gone into a fail-safe condition. During the fail-safe condition, the current will increase up to 22 mA and hold until the acoustic signal is reacquired. Once reacquired, the LED will turn back ON continuously and the current will indicate the appropriate measured value.



CALIBRATION


Step Seven

Current to Distance Conversion Chart (Nominal)

Current mA	Distance inches	Current mA	Distance inches	Current mA	Distance inches
20	03.6	14	29.2	08	54.9
19	07.9	13	33.5	07	59.2
18	12.1	12	37.8	06	63.5
17	16.4	11	42.1	05	67.7
16	20.7	10	46.3	04	72.0
15	25.0	09	50.6		

Distance to Current Conversion Chart (Nominal)

Distance inches	Current mA	Distance inches	Current mA	Distance inches	Current mA
3.6	20.0	30	13.8	60	06.8
06	19.4	36	12.4	66	05.4
12	18.0	42	11.0	72	04.0
18	16.6	48	09.6		
24	15.2	54	08.2		



MAINTENANCE

Step Eight

General:

The LVCN-90 series level transmitter itself requires no periodic maintenance except cleaning as required. It is the responsibility of the user to determine the appropriate maintenance schedule, based on the specific characteristics of the application liquids.

Cleaning Procedure:

- 1. Power: Make Sure that all power to the transmitter, controller and/or power supply is completely disconnected.
- Sensor Removal: In all through-wall installations, make sure that the tank is drained well below the sensor prior to removal. Carefully, remove the sensor from the installation.
- 3. Cleaning the Sensor: Use a soft bristle brush and mild detergent, carefully wash the transducer of the LVCN-90. Do not use harsh abrasives such as steel wool or sandpaper, which might damage the transmitter's surface. Do not use incompatible solvents which may damage the PVDF transducer or the transmitter's PP body.
- 4. Sensor Installation: Follow the appropriate steps of installation as outlined in the installation section of this manual.

	-	Step	Nine
1			